

**DMT Milieutechnologie BV**  
P.O. Box 231 8440 AE Heerenveen  
Yndustrywei 3 8501 SN Joure (NL)  
THE NETHERLANDS  
<http://www.dirkse-milieutechniek.com>  
2009

**“DMT IWOX® 2 TANK SYSTEM”**

Daily hydraulic flow:		1.2 m <sup>3</sup> /d
Material:		Polyethylene (PE)
Watertightness (water test):		pass
Crushing resistance:		pass
Treatment efficiency:	COD:	90.3 %
(Nominal Sequences only)	BOD <sub>5</sub> :	97.5 %
	TSS:	96.7 %
Nitrogen Parameters:		NPD
Electrical consumption:		1.92 kWh/d
pH:		7.7
Sludge production:		NPD

Date: September 24, 2009

Signature

  
Drs. G. Brill